

Parkunit	Total Hours	Active Prod. Total kWh	Active Consumption kWh	Active Prod. Generator 1 kWh	Active Prod. Generator 2 kWh	Reactive Prod. Total kVArh	Capacity Factor %
WTG01 (99.6%)	738.7	1,165,394.1	-2,945.3	1,168,338.5	0.0	-730.3	47.44
WTG02 (99.7%)	739.2	1,199,362.8	-2,680.4	1,202,043.1	0.0	-169.4	48.85
WTG03 (99.6%)	739.2	1,201,489.2	-2,732.4	1,204,221.5	0.0	-477.2	48.94
WTG04 (99.6%)	739.0	1,217,211.4	-2,563.9	1,219,775.3	0.0	-431.9	49.58
WTG05 (99.7%)	739.7	1,184,133.8	-2,634.2	1,186,768.1	0.0	3,714.3	48.23
WTG06 (99.1%)	735.3	1,167,939.3	-2,766.7	1,170,706.1	0.0	3,521.0	47.57
Total	4,431.1	7,135,530.6	-16,322.9	7,151,852.6	0.0	5,426.5	
Min	735.3	1,165,394.1	-2,945.3	1,168,338.5	0.0	-730.3	47.44
Avg	738.5	1,189,255.1	-2,720.5	1,191,975.4	0.0	904.4	48.44
Max	739.7	1,217,211.4	-2,563.9	1,219,775.3	0.0	3,714.3	49.58
Std.Dev	1.6	20,412.4	131.4	20,309.4	0.0	2,110.1	

Report details

Period from	Period to	Integrity	Report type	Template
2018-01-01 00:10:00	2018-02-01 00:00:00	100	Standard	Standard Production Report (VMP)

Park units

WTG01 (99.6%), WTG02 (99.7%), WTG03 (99.6%), WTG04 (99.6%), WTG05 (99.7%), WTG06 (99.1%)

Description

