

Georgia Gori

Report period: 5/1/2018 12:10 AM to 6/1/2018

Generated on: 7/25/2018 10:19 AM

Printed on: 7/25/2018 10:21

Generated by: Tornike Kazarashvili (TORNIKE)

Page: 1

Parkunit	Total	Active Prod.	Active	Active Prod.	Active Prod.	Reactive Prod.	Capacity
	Hours	Total kWh	Consumption kWh	Generator 1 kWh	Generator 2 kWh	Total kVArh	Factor %
WTG01	742.5	867,614.8	-2,612.6	870,229.0	0.0	-371.0	35.33
WTG02	742.7	857,597.0	-2,542.4	860,139.9	0.0	-369.5	34.93
WTG03	740.5	850,634.5	-2,524.6	853,159.5	0.0	-474.9	34.65
WTG04	742.8	880,782.1	-2,608.7	883,389.7	0.0	-387.1	35.87
WTG05	742.3	862,295.1	-2,631.6	864,924.7	0.0	-367.0	35.12
WTG06	742.5	848,755.5	-2,575.3	851,331.1	0.0	-589.7	34.58
Total	4,453.3	5,167,679.0	-15,495.2	5,183,173.9	0.0	-2,559.2	
Min	740.5	848,755.5	-2,631.6	851,331.1	0.0	-589.7	34.58
Avg	742.2	861,279.8	-2,582.5	863,862.3	0.0	-426.5	35.08
Max	742.8	880,782.1	-2,524.6	883,389.7	0.0	-367.0	35.87
Std.Dev	0.9	11,876.4	42.5	11,903.1	0.0	89.9	

Report details

Period from	Period to	Integrity	Report type	Template
2018-05-01 00:10:00	2018-06-01 00:00:00	100	Standard	Standard Production Report (VMP)

Park units

WTG01, WTG02, WTG03, WTG04, WTG05, WTG06

Description

